



**SOUTHERN  
SOIL  
CONSULTANTS,  
LLC**

4/21/23

Gary Hardison  
527 Hyman Road  
New Bern, NC 28562

RE: Just Past 14515 Western Mill Road on the Right  
TMP: 54-25  
Size: 40 Acres total

Dear Gary,

Your request for a certification letter for the above referenced property has been evaluated in accordance with the requirements contained in the Code of Virginia, Section 32.1-163, The Sewage Handling and Disposal Regulations.

Based on the site and soil evaluation, the soils are suitable to accommodate a conventional drainfield for a three (3)-bedroom dwelling at 450 gallons/day. The exact placement and design will be determined at the time of permitting.

If you have any questions, please contact our office at the number listed below.

Sincerely,

Brian H. Neal  
OSE # 1940-001181



Interest Point A - Gary Harrison 1  
Description  
Latitude: 36° 45' 18.4710" N  
Longitude: 77° 47' 4.50188" W  
Altitude: 294.37 ft



Interest Point C - Gary Harrison 3  
Description  
Latitude: 36° 45' 18.8858" N  
Longitude: 77° 47' 4.6892" W  
Altitude: 304.23 ft

Interest Point B - Gary Harrison 2  
Description  
Latitude: 36° 45' 17.6634" N  
Longitude: 77° 47' 5.8142" W  
Altitude: 296.55 ft



106-1000

106-1001

106-1002

231