

**AUTHORIZATION FOR WASTEWATER
SYSTEM CONSTRUCTION
ALLAN THOMAS SMITH
PAGE 2**

CONDITIONS:

1. Installation of the wastewater system shall be in strict accordance with the Improvement Permit #9399-10 and all specifications thereof and the site plan submitted by Allan Thomas Smith.
2. The wastewater system is designed to serve a 3 bedroom house. The number of bedrooms in the garage will be deducted from this total if a future home is to be constructed.
3. The wastewater system is for a single family dwelling only and will not accommodate a duplex. At such time a home is built, the garage is to be an integral part of the house.
4. The lot is to be cleared with as little disturbance to the naturally occurring soil as possible especially in the area where the drainfield is to be located.
5. Install the property line swales and landscape the entire lot to rid surface water prior to any construction.
6. Place a 6" cap of topsoil over the drainfield to extend 5' past the trench sidewalls prior to tapering. Shape to shed surface water and establish a grass cover. Maintain grass height not to exceed 3"-4".
7. Use water conserving fixtures i.e. 1.6 gallon flush toilets, 2 gpm shower heads, 1 gpm all lavatories. Do not pour grease or harsh cleaning chemicals into the house drains. Try to spread out laundry loads throughout the week.

This Authorization For Wastewater System Construction shall be valid for 5 years from the date of issuance.

Heidi Watson, LEHS
Environmental Health Specialist

1-26-11
Date