

2004120012

Application date: 12/13/2004

SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL  
PERMIT TO CONSTRUCT-CERTIFICATE OF FINAL APPROVAL  
INDIVIDUAL SEWAGE TREATMENT AND DISPOSAL SYSTEM

LARRY SCHOTT  
8710 CRESTVIEW DR

Subdivision: WYBOO POINTE  
Lot and Block No: 168 & 169  
Tax Map Number: 196-03-00-041  
Site: ROCKFISH DR  
Contractor:

WAXHAW NC 28173  
Water Supply: PUBLIC Facility: HOUSE  
Receipt No: 1414648

SYSTEM SPECIFICATIONS

Est. Daily Flow: 360 gpd  
Loading rate: 0.80 g/ft<sup>2</sup>  
Tank Size(s): 1000 gal  
Permitted System: 100  
Permit Date: 01/10/2005 By: 16

Trenches: No: 3  
Total length: 150 ft  
Width: 36 in  
Maximum depth: 23 in  
Material:  
Depth: 14 in  
Min pump cap: NA gpm  
at NA ft head.

SPECIAL INSTRUCTIONS

**\*NOT TO SCALE!\***

**NO DRIVING OVER SYSTEM**

System must be 50 ft. min. from all private wells/100 ft. min. from all public wells.


ACTUAL INSTALLATION

Tank Manufacturer: \_\_\_\_\_  
Pipe Manufacturer: \_\_\_\_\_  
Pump Manufacturer: \_\_\_\_\_

Nearest Actual Distances to:  
Well: \_\_\_\_\_ ft  
Foundation: \_\_\_\_\_ ft  
Property Line: \_\_\_\_\_ ft  
Stream: \_\_\_\_\_ ft  
Impoundment: \_\_\_\_\_ ft  
Line No. Grade Readings

Line No.	Grade Readings

SKETCH OF RECOMMENDED INSTALLATION



SKETCH OF ACTUAL INSTALLATION

APPROVAL IN NO WAY GUARANTEES THE LIE OF THE SYSTEM OR THAT IT WILL FUNCTION PROPERLY UNDER ANY OR ALL CONDITIONS.

Issued by: [Signature] Date: 01/10/2005 Code Number: 16

Approved by: \_\_\_\_\_ Date: / / Code Number: \_\_\_\_\_

CLARENDON COUNTY HEALTH DEPARTMENT  
MANNING, SC 29102

110 E BOYCE ST  
(803) 435-2592