

Wendy's Onsite Evaluation & Design, L.L.C.

Wendy Odom, OSE # 1940001152
433 Pleasant Grove Rd
Seaboard, NC 27876
757-635-6229
252-578-2774

November 30, 2022

Caleb Hooker

RE: Tax Parcel #: 06-01-066 Pt Of
Property location: Old Stage Hwy

Dear Mr. Hooker:

Soil evaluations have been conducted on a portion of the above referenced Tax Parcel. My findings showed soils with a seasonal water table 16-24 inches from the ground surface with an estimated percolation rate of 45-60 minutes per inch. These soils are typically suitable for an Alternative Onsite Sewage System utilizing TL-2 treatment or TL-3 treatment. Please understand that no specific drainfield footprint was established. The soil borings conducted are site specific. Enclosed is my fee for work completed to date. This amount will be credited toward any design package. Please be advised that my fees do not include any local City/ County fees or Health Department fees, if any. These fees will be your responsibility when you file an application for a Construction Permit with the local Health Department. If you have any questions regarding this documentation, please contact me.

Sincerely,

Wendy Odom
OSE # 1940001152