



**ALAMANCE COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION**



Improvement Permit- New

A Construction Authorization must be purchased to obtain a building permit (This is not a Construction Authorization)

Tax Map Number 3-23B-3	GPIN 8843474345	Application Date 1/4/2023	Permit Number 7372IMPR23
----------------------------------	---------------------------	-------------------------------------	------------------------------------

Site Address 0 HOWLE DR. ,

Directions HUFFMAN MILL RD PAST ROCK QUARRY TO GREESON TO HOWLE

Applicant BACKWOODS LAND LLC 3095 CHAMPS WAY MEBANE, NC 27302 (336) 213-9663	Owner HANFORD MARVIN LON 5054 PO BOX EMERALD ISLE, NC 28594 (252) 646-3395
Phone	Phone
Fax	Fax
Other	Other
Email backwoodslandco@gmail.com	Email

Type of Structure	HOUSE	Basement	No
Pump Required	Yes	Basement Plumbing	No
Grease Trap Required	No	Number of Bedrooms	3
Projected Daily Flow	360 GPD	Number of Occupants	6
Permit Valid For	Expires 5/1/2028	Type of Water Supply	Well

Wastewater System Type	Pump Type IIIb
System Description	Pump to 25% Reduction Septic System with Shallow Placement
System Distribution	PRESSURE MANIFOLD
Repair System Type	N/A
Repair Description	
Repair System Distribution	n/a

LTAR	0.225
Usable soil depth to Limiting Condition for Initial area	24 inches
Usable soil depth to Limiting Condition for Repair area	0 inches
Minimum Trench Depth	12 inches
Maximum Trench Depth	12 inches

Permit Conditions:
Additional soil cover needed
Other: DO NOT CUT OR FILL PERMITTED AREA. NO UTILITIES SHALL BE INSTALLED IN THE PERMITTED SEPTIC SYSTEM AREAS. ADDITIONAL SOIL COVER MATERIAL MUST BE APPROVED BY ALAMANCE COUNTY ENVIRONMENTAL HEALTH.
All pump designs and installations shall be in accordance with the Laws and Rules for Sewage Treatment, and Disposal Systems 15A NCAC 18A .1900 subject to approval by Alamance County Health Department.

See Attached Site Sketch

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. *This permit is subject to revocation if the site plan, plat, or the intended use changes.* The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.

Authorized State Agent Rob Snow

Date 5/1/2023