

Northampton County Health Department

File/Permit Number: 7573

IMPROVEMENT PERMIT

County: Northampton
 PIN/Lot Identifier: 0405118
 Owner: Michael J. Heerp Applicant: _____
 Property Location: Oceanushee Neck Road North between 541 & 641
 Subdivision (if applicable) Heerp Acres Lot #: 3 Block: — Section: —
 New ☒ Expansion ☐ System Relocation ☐ Change of Use ☐
 Facility Type: Single Family Residence
 Number of bedrooms: 3 Number of Occupants: 6 Other: _____
 Design Wastewater Strength: ☒ Domestic ☐ High Strength ☐ Industrial Process Wastewater
 Proposed Design Daily Flow: 360 GPD Proposed LTAR (Initial): _____ Proposed LTAR (Repair): _____
 Proposed Wastewater System Type*: III by SLT horizontal MADS w/pump (Initial) Pump Required: ☒ Yes ☐ No ☐ May be required
 Proposed Wastewater System Type*: III by SLT horizontal MADS w/pump (Repair) Pump Required: ☒ Yes ☐ No ☐ May be required
 *Please include system classification for proposed wastewater system types in accordance with Rule .1301 Table XXXII
 Effluent Standard: ☒ DSE ☐ HSE ☐ NSF/ANSI 40 ☐ TS-I ☐ TS-II ☐ RCW
 Saproliite System (Initial): ☐ Yes ☒ No Saproliite System (Repair): ☐ Yes ☒ No
 Fill System (Initial): ☐ Yes ☒ No If yes, specify: ☐ New ☐ Existing (when adding more than 6 inches of fill to system area provide a fill plan)
 Fill System (Repair): ☐ Yes ☒ No If yes, specify: ☐ New ☐ Existing (when adding more than 6 inches of fill to system area provide a fill plan)
 Usable Depth to LC (Initial)*: 140" Usable Depth to LC (Repair)*: 140" * Limiting Condition
 Max. Trench Depth (Initial)*: 140" + 5' 11" Max. Trench Depth (Repair)*: 140" + 5' 11" * Measured on the downhill side of the trench
 Artificial Drainage Required: ☐ Yes ☒ No If yes, please specify details: _____
 Type of Water Supply: ☐ Private well ☐ Public well ☐ Shared well ☒ Municipal Supply ☐ Spring ☐ Other: _____
 Drainfield location meets requirements of Rule .0508: Yes ☒ No ☐ Drainfield location meets requirements of Rule .0601: Yes ☒ No ☐
 Permit valid for: ☒ Five years [site plan submitted pursuant to GS 130A-334(13a)] ☐ No expiration [plat submitted pursuant to GS 130A-334(7a)]

Permit conditions:

* Pre-construction meeting w/ landowner, contractor, & LHD required prior to the issuance of a CA.
 * Trees must be cleared prior to the issuance of a CA, take great care not to disturb soil when clearing trees.
 * See Report from State Regional Consultant, Tom Coleman

Authorized Agent's Printed Name: Katie HowardExpiration Date: 12-2-29Authorized Agent's Signature: [Signature]Date: 12-2-24

See attached site sketch → see 6 pgs report

The issuance of this permit in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This permit is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of 15A NCAC 18E and to the conditions of this permit.